

ISSUE	REF.	REQMT.	DATA / COMMENTS
-------	------	--------	-----------------

USE / OCCUPANCY CLASSIFICATION				Chapter 3
Classification	303			
SPECIAL REQUIREMENTS				Chapter 4
Atriums	404			
Garages	406			
Stages and platforms	410			
Review other sections				
HEIGHT & AREA LIMITS				Chapter 5
Definitions	502		Basement, grade plane, mezzanine	
General limits	503			
Allowable limits	T503			
Mezzanines	505			
Area modifications	506			
Unlimited area buildings	507			
Incidental use areas	508.2			
Mixed occupancies	508.3			
Req'd separation	T508.3.3			
CONSTRUCTION TYPE				Chapter 6
Fire rating of building elements	T601			
Fire rating of exterior walls	T602			
Allowable combustible materials in Types I and II	603			

ISSUE	REF.	REQMT.	DATA / COMMENTS
-------	------	--------	-----------------

FIRE-RATED CONSTRUCTION	Chapter 7
--------------------------------	------------------

Buildings on same property / have courts	704.3		
Maximum wall openings	T704.8		
Parapets required	704.11		
Fire wall ratings	T705.4		
Fire barriers	706		
Shaft enclosures	707		
Elevator lobbies	707.14.1		
Fire partitions	708		
Smoke barriers	709		
Penetrations	712		
Fire-resistant joint systems	713		
Bottom flange protection	714.6		

INTERIOR FINISHES	Chapter 8
--------------------------	------------------

Finish requirements by occupancy	T803.5		
----------------------------------	--------	--	--

FIRE PROTECTION SYSTEMS	Chapter 9
--------------------------------	------------------

Sprinklers	903		
Standpipes	905		
Fire extinguishers	906		
Fire alarms	907.2		
Manual fire alarm boxes	907.3		

ISSUE	REF.	REQMT.	DATA / COMMENTS
-------	------	--------	-----------------

MEANS OF EGRESS		Chapter 10	
Floor area / occupant	1004.1		
Posting occ load	1004.3		
Egress width	1005.1		
Elevation change	1003.5		
Exit signs	1011		
Accessible means of egress	1007		
Doors	1008		
Stairways	1009		
Stair width	1009.1		
Treads & risers	1009.3		
Outdoor conditions	1009.5.2		
Handrails	1012		
Ramps	1010		
Number of exit access	1015.1		
Travel distance	1016.1		
Corridors	1017		
Number of exits	1019.1		
Stair enclosures	1020.1		
Horizontal exits	1022		
Exterior exit stairs	1023		
Misc means of egress requirements	1015.3-10 15.6.1		
Assembly uses	1025		

ISSUE	REF.	REQMT.	DATA / COMMENTS
-------	------	--------	-----------------

ACCESSIBILITY	Chapter 11
----------------------	-------------------

Exceptions	1103.2		
Accessible parking	T1106.1		
See ADA			

INTERIOR ENVIRONMENT	Chapter 12
-----------------------------	-------------------

Natural ventilation	1203.4		Min openable area is 4% of flr area being ventilated
Natural light	1205.2		Min glazed area is 8% of flr area of room served

ENERGY EFFICIENCY	Chapter 13
--------------------------	-------------------

See IECC			

EXTERIOR WALLS	Chapter 14
-----------------------	-------------------

Water-resistv barrier	1404.2		
Min. thicknesses	T1405.2		

ROOF ASSEMBLIES	Chapter 15
------------------------	-------------------

Fire classification	T1505.1		
Shingles	T1507.8		Wood shingles shall be installed on slopes of three units vertical in 12 units horizontal (3:12) or greater.

ISSUE	REF.	REQMT.	DATA / COMMENTS
Metal panels	T1507.4.3		1. The minimum slope for lapped, nonsoldered seam metal roofs without applied lap sealant shall be three units vertical in 12 units horizontal (25-percent slope). 2. The minimum slope for lapped, nonsoldered seam metal roofs with applied lap sealant shall be one-half unit vertical in 12 units horizontal (4-percent slope). Lap sealants shall be applied in accordance with the approved manufacturer's installation instructions. 3. The minimum slope for standing seam of roof systems shall be one-quarter unit vertical in 12 units horizontal (2-percent slope). (Section 1507.4.2)
"Flat" roofs	1507.10...		Built-up roofs shall have a design slope of a minimum of one-fourth unit vertical in 12 units horizontal (2-percent slope) for drainage, except for coal-tar built-up roofs that shall have a design slope of a minimum one-eighth unit vertical in 12 units horizontal (1-percent slope). (Section 1507.10.1)
STRUCTURAL DESIGN			Chapter 16
Building classification	T1604.5		Review w/ engineer
Live loads	T1607.1		Review w/ engineer
SPECIAL INSPECTIONS			Chapter 17
Steel inspections	T1704.3		Applies if over 25,000SF or 15' high
Concrete inspections	T1704.4		
Level 1 inspections	T1704.5.1		Applies to non-essential facilities
Level 2 inspections	T1704.5.3		Applies to essential facilities