

AGENDA

Date: October 17, 2009
To: Geograph
cc:
Re: **Interior shop drawings and signage samples**
From: RICK WOLNITZEK, Wolnitzek Architects

Included (but not limited to) is a list of comments for the Interior signage shop drawings and signage samples. Note that APCO Accord system is the basis of design, and we expect to see an equal quality.

Samples:

1. All three sign samples have some text distortion.
2. There are scratches on the frames as well as the plexi-glass signs.
3. The directory sign is not sufficiently rigid causing bowing in strips.
4. The slider is not straight and does not look clean.
5. The top edge should be finished. Construction and mounting methods should not be visible.
6. Dark gray color is not an acceptable match
7. 1/8" frame where called out.
8. Fire Stair symbol doesn't match industry standard, nor shop drawings.
9. The paper does not slide into the sign slot.
10. Red and Green paints do not match color selected. View in both sun and shade.

Drawings:

1. Show all details related to fabrication and assembly at an appropriate scale.
2. Show all correct sign materials and text materials, and methods used.
3. Show how to insert paper into slotted signs.

